

ADDENDUM NO. 7- OSHPD ITEM 27-3
PAGE 142 OF THE SEPTEMBER 1999 MONOGRAPH

**SUB-ITEM 27-3 APPROVED As
Submitted**

PART 4, CHAPTER 14

SECTION 1407, PART 5, CHAPTER 3

REPEAL SECTION 1407 AS FOLLOWS:

**CALIFORNIA MECHANICAL CODE
CHAPTER 14
SPECIAL PIPING AND STORAGE SYSTEMS**

**AT THE MAY 24, 2000 MEETING
THE COMMISSION APPROVED
OSHPD's ITEM 27, SUB-ITEM 27-
3 AS SUBMITTED.**

**~~Section 1407 — Medical Gas Piping [FOR
OSHPD 1, 2, 3 & 4]~~**

~~All medical gas piping shall have all burrs removed. Pipe ends shall be reamed and all chips removed. Piping shall then be cleaned in accordance with NFPA 99 requirements.~~

ADOPT NEW SECTION 320 AS FOLLOWS:

**CALIFORNIA PLUMBING CODE
CHAPTER 3
GENERAL REGULATIONS**

319.0 Test Gauges. Tests required by this Code,

320.0 Medical Gas Piping [For OSHPD 1, 2, 3 & 4] All medical gas piping shall have all burrs removed. Pipe ends shall be reamed and all chips removed. Piping shall be cleaned in accordance with National Fire Protection Association(NFPA) 99, 1996 edition.